



ANALYTICAL RESULT(S) (results apply to samples as received)

Customer : Serene Water Estate
Sample Type : Drinking Water
Attention : Ms Zaina

Date Received : 30/07/2018
Date Reported : 01/08/2018

Sample Delivered by Courier

Customer I.D Lab No.	Drinking Water	Acceptable Level	Method Ref. No.
Sodium (mg/L)	28	< 200	AP3500-Na B
Calcium (mg/L)	29	< 100	AP3111B
Magnesium (mg/L)	14	< 30	AP3111B
pH (units)	7.1	6.5 – 8.5	AP4500-H+B
Total Dissolved Solids (mg/L)	290	< 1000	AP2540C (modified)
Silica (mg/L)	45	n.a.	AP4500-SiO ₂ D
Heterotrophic Plate Count (cfu/mL)	< 1 est	100	AP 9215B
Total Coliform (cfu/100mL)	< 1	< 1	AP 9222B

Note 1 : APHA 22nd Edition, 2012

Note 2 : Acceptable Level = WHO guidelines for drinking water, 2011


Anjila Nand
Key Technical Person

01/08/2018
Date